



CONVENTIONAL FIRE ALARM PANEL FP9000L-2/4/6/8



TECHNICAL CHARACTERISTICS

LINES				
> Lines:				
Number of lines	2, 4, 6 or 8	Optional		
Maximum number of fire detectors in a line	32			
Type of the joining line	biconductional			
Plume maximum resistance	100 Ω			
Current thresholds in the lines:				
Interruption	from 1 to 4 mA			
Duty mode	from 5 to 16 mA			
• Fire	from 17 to 70 mA			
Fire direct /without delay outputs/	from 40 to 70 mA			
Short circuit	> 70 mA			
Lines functional characteristics:				
• Verification quantity before entering Fire mode:	2			
Verification and regestrating fault in a earth conductor	yes	selectively		
OUTPUTS				
> Independent relay output in case of fire alarm:				
Quantity	1			
• Type	switching	NC/NO		
Electrical characteristics	3A/125V AC, 3A/30V DC			
> Controllable output in case of fire alarm:				
Quantity	2			
• Type	potentional relay			

	(10.20) UDC/ 0.5 A			
Electrical characteristics	(19-28)VDC/ 0,5A			
Additional relay outputs (modul M9000		e alarm:		
• Quantity	2/4/6/8	NG NG		
• Type	potentional-free	NC or NO		
Electrical characteristics	3A/125V AC, 3A/30V DC			
> Independent relay output in case of failure:				
Quantity	1			
• Type	potentional-free, switching	NC / NO		
Electrical characteristics	3A/125V AC, 3A/30V DC			
Delay outputs:				
Time delay of switching outputs	0 ÷ 7 minutes			
POWER SU	PPLY			
Mains power				
• Voltage	(187-252)V AC			
Frequency	50/60 Hz			
Maximum power to mains power	38W / AC			
> Battery power				
Battery quantity	2			
Type of the battery	Lead, gel			
Battery rated voltage	12V DC			
Reted power C20	1.3Ah, 4.5Ah, 5 Ah			
Charger voltage	27,6 VDC	temperature compensated		
Consumption of battery po				
Configuration with 2 lines	< 40 mA to 24 VDC			
Configuration with 4 lines	< 50 mA to 24 VDC			
• Configuration with 6 lines	< 60 mA to 24 VDC			
Configuration with 8 lines	< 70 mA to 24 VDC	1057/541		
Time needed in security mode when mains pow		battery 12V/5Ah		
• Configuration with 2 lines	120h 90h			
Configuration with 4 lines Configuration with 6 lines	80h			
Configuration with 6 linesConfiguration with 8 lines	72h			
Configuration with 8 lines Time needed in security mode when mains pow		hattary		
12V/1.3Ah	ci suppry is down with	Dattery		
• Configuration with 2 lines	32h			
Executive devices	l			
Voltage	(19-28)V DC			
Maximal current (including the controllable outputs current)	1A			
Fuses				
Mains power 230V AC	4,0 A fusible			
Battery power	4,0 A fusible			
Powering external devices	1,85 A automatic			
Controllable outputs	1,1 A automatic			
Functional char				

- Control of the lines and controllable outputs for fault conditions (short circuit and interruption) and automatic reset;
- Ability to delay controllable and general outputs for fire for a period of **0 to 7 minutes** after the registration of state Fire with DIP switch;
- Built-in sounder in case of fire monotonal, continuous with the possibility of exclusion;
- Test mode of each (fire alarm) lines;
- Ability to Disable each of the fire alarm lines;
- Ability to Disable controllable outputs for fire;
- Interface for communication with external devices RS485 and networking / optional /;
- Possibility for GPRS/LAN communication and remote control and monitoring / optional /;
- Possibility Ability to add module relay M9000R-2/4/6/8. The module expands the outputs of the Panel.

of the ranet.				
Over all size	310x240x80 mm			
Weight without batteries	1,25 kg			
> Safety degree	IP30/ EN 60529			
The panel meets standarts:				
• EN 54-2:1997				
• EN 54-2:1997/A1:2006				
• EN 54-2:1997/AC:1999				
• EN 54-4:1997				
• EN 54-4:1997/A1:2002				
• EN 54-4:1997/A2:2006				
• EN 54-4:1997AC:1999				
• EN 50130-4:2011				
• EN 55022:2006/A1:2007				

DELIVEERY COMPOSITION AND COMPLEXITY/SET

EN 60950-1:2006/A11:2009

• Fire Station FP 9000L	1 qty.
• EOL - resistor $4.7k\Omega/0.5W$:	
- for configuration with 2 lines /FP9000-2/	2 qty.
- for configuration with 4 lines /FP9000-4/	4 qty.
- for configuration with 6 lines /FP9000-6/	6 qty.
- for configuration with 8 lines /FP9000-8/	8 qty.
• (EOL) End for controllable output - resistor $4.7k\Omega/0.5W$;	2 qty.
• Fuse 4,0A;	2 qty.
Connective bridge for batteries;	1 qty.
Packaging.	1 qty.

TERMINALS

